Air Resources Board

Alan C. Lloyd, Ph.D.
Chairman
2020 L Street • P.O. Box 2815 • Sacramento, California 95812 • www.arb.ca.gov

Winston H. Hickox
Secretary for Environmental Protection

Gray Davis
Governor

April 15, 1999

Mr. Tom Hearon
Branch Manager
Ace Tank & Equipment
6125 NE Portland Highway
Portland, Oregon 97218

Dear Mr. Hearon: #AGT 99-02

Air Resources Board Executive Order G-70-137

This letter is in response to your letter dated March 23, 1999 in which you requested California Air Resources Board (CARB) clarification of the subject executive order as it applies to certified tank capacity.

As you stated in your letter, the Executive Order limits the total size of the gasoline storage capacity of aboveground storage tanks to 6,000 gallons and the capacity of the gasoline compartment(s) of a split product tank to 6,000 gallons total gasoline capacity. A split product tank, therefore, can have a total product capacity of 12,000 gallons as long as the total gasoline component compartment(s) capacity is 6,000 gallons or less.

If you have any questions, please contact Mr. Gary Zimmerman of my staff at (916) 322-2886.

Sincerely,

James J. Morgester, Chief
Compliance Division